



NOTES:

1. WATER STOPS TO BE CONSTRUCTED UPSTREAM OF MANHOLES AND AT 500' MAXIMUM SPACING IN GROUNDWATER CONDITIONS AND WHERE TYPE 'C' BEDDING IS USED, OR OTHER LOCATIONS IDENTIFIED BY THE ENGINEER.
2. WRAP PIPE WITH "RAM-NEK", OR EQUAL, WHERE PIPE IS EXPOSED TO CONCRETE PRIOR TO POURING.
3. EXCAVATION & BACKFILL SHALL BE AS SPECIFIED IN TRENCH DETAIL, DRAWING No. W-207 OR DRAWING No. W-302.
4. USE TYPE 'B' CONCRETE SLURRY.

DATE	REVISIONS



STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION

CUT-OFF COLLAR

SECTION NUMBER: 200
DRAWING NUMBER: W-227
DATE: 2/21/2022