


NOTES:

1. ALL SERVICE LINE COUPLING FITTINGS SHALL BE MUELLER IPS 110 COMP. X MIP, OR APPROVED EQUAL.
2. ALL SERVICE VALVES SHALL BE SAME SIZE AS SERVICE LINES.
3. SERVICE CLAMPS SHALL BE FACTORY COATED EPOXY WITH STAINLESS STEEL BAND.
4. MINIMUM DISTANCE BETWEEN TAPS AND MAINLINE FITTING, INCLUDING BELLS, SHALL BE 18”.
5. ENTITY REQUESTING ABANDONMENT SHALL REMOVE EXISTING WATER BOX AND EXPOSE CORPORATION STOP FOR SHUT-OFF. ALL PLUMBING SHALL BE DISCONNECTED FROM CORPORATION AND PLUGGED AT BOTH ENDS. WATER UTILITY SHALL BE NOTIFIED FOR INSPECTION OF CORPORATION ASSEMBLY PRIOR TO BACKFILLING.
6. UPON ABANDONING OF SERVICE TAP, WATER UTILITY SHALL BE NOTIFIED SO THE METER CAN BE REMOVED.
7. TAPPING SADDLE MUST BE AT 45° ANGLE. EXCEPTIONS MUST BE APPROVED BY THE COUNTY ENGINEER.
8. ALL METER SETS TO BE PLACED A MAXIMUM OF 5’ FROM BACK FACE OF CURB. IN AREAS WHERE NO CURB IS PRESENT, THE FRONT OF THE METER IS TO BE SET AS DIRECTED BY THE COUNTY ENGINEER.

DATE	REVISIONS		STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION WATER SERVICE TAP & LINE NOTES	SECTION NUMBER:
				300
				DRAWING NUMBER: W-310B
				DATE: 2/21/2022