

NOTES:

1. THRUST BLOCKS TO BE CONSTRUCTED OF 4000 PSI CONCRETE PER THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (SSPWC).
2. MINIMUM AREAS GIVEN ARE FOR PRESSURE CLASS 235 PIPE AT TEST PRESSURE OF 150 PSI, WITH 2000 PSI BEARING CAPACITY. INSTALLATIONS USING DIFFERENT PIPE, TEST PRESSURES, AND/OR SOIL TYPES SHOULD ADJUST AREAS ACCORDINGLY, SUBJECT TO APPROVAL OF ENGINEER.
3. BLOCKS TO BE POURED AGAINST UNDISTURBED SOIL.
4. JOINTS AND FACE OF PLUGS TO BE KEPT CLEAR OF CONCRETE.
5. WRAP ALL FITTINGS WITH POLY-WRAP PRIOR TO CONCRETE PLACEMENT.

DATE	REVISIONS		STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION NUMBER:	
				THRUST RESTRAINT	300
				NOTES	DRAWING NUMBER:
					W-320B
				DATE:	
				2/21/2022	