

Water Quality Data, continued.

Radionuclides	Collection Date	Compliance Value	Range	Unit	MCL	MCLG	Typical Source
GROSS ALPHA PARTICLE ACTIVITY	2005	8	ND - 8	pCi/L	15	0	Decay of natural and man-made deposits
GROSS BETA PARTICLE ACTIVITY	2005	11	3 - 11	pCi/L	50	0	Decay of natural and man-made deposits
RADIUM, COMBINED (226, 228)	2005	1	ND - 1	pCi/L	5	0	Erosion of natural deposits
RADON	2006	775	584 - 775	pCi/L	No MCL		Erosion of natural deposits
URANIUM	2007	3	1 - 3	ppb	30	0	Erosion of natural deposits

Secondary Regulated Contaminants	Collection Date	Compliance Value	Range	Unit	Secondary Standard
ALKALINITY	2005	120	110 - 120	ppm	No MCL
CALCIUM	2005	20	20	ppm	No MCL
CHLORIDE	2008	17	1.1 - 17	ppm	400
IRON	2005	0.12	ND - 0.12	ppm	0.6
MAGNESIUM	2008	13	12 - 13	ppm	150
MANGANESE	2007	0.01	ND - 0.01	ppm	0.1
PH	2007	8.17	7.81 - 8.17	pH	6.5-8.5
SODIUM	2008	18	8.8 - 18	ppm	No MCL
SULFATE	2008	3.8	1.6 - 3.8	ppm	500
TOTAL DISSOLVED SOLIDS (TDS)	2008	200	180 - 200	ppm	1000
ZINC	2007	0.022	ND - 0.022	ppm	5

Microbiological	Result	MCL	MCLG	Typical Source
No detected results were found in the calendar year of 2009.				

Violations

During the 2009 calendar year, the Thomas Creek Public Water System had no violations.

Contact information

If you have any questions regarding water quality or the material in this report, please contact the Washoe County Department of Water Resources at: 4930 Energy Way Reno, NV 89502 (775) 954-4612 www.washoecounty.us/water



Printed with Vegetable Oil Based Inks on 30% Post Consumer Content Paper

THOMAS CREEK PUBLIC WATER SYSTEM Consumer Confidence Report – 2010 Covering Calendar Year – 2009



The Washoe County Department of Water Resources is a leader in providing integrated water resources. These services are critical to the region's quality of life. They include utility services (water, sewer, and reclaimed water) and water resource planning services (flood management, remediation of contaminated groundwater, and development of water resource plans).

The Department of Water Resources is committed to be the leader in the provision of integrated water resource services to our community. Our mission is to provide quality product and service to our community through teamwork, accountability and professionalism.

Regular testing of the water resources is one way we fulfill that mission. This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. It is important that customers be aware of the efforts that are continually being made to improve their water systems.

Your water comes from:

Source Name	Source Water Type
Thomas Creek Well 1	Ground Water
Consecutive Connection from Arrowcreek Public Water System NV000901	Ground Water

Your drinking water is supplied from groundwater sources and through a Consecutive Connection (CC) with the Arrowcreek Public Water Systems. We add disinfectant to protect you against microbial contaminants. The Safe Drinking Water Act (SDWA) requires states to develop a Source Water Assessment (SWA) for each public water supply that treats and distributes raw source water in order to identify potential contamination sources. The state has completed an assessment of your source water. For results of the Source Water Assessment, please contact the Department of Water Resources at (775) 954-4612.

Message from EPA

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as those with cancer under going chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. We aim to provide water that meets EPA's regulations. We treat your water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Well Head Protection Program

Much of the water we use everyday comes from groundwater wells operated by the Washoe County Department of Water Resources. Well Head Protection Programs (WHPPs) help ensure the safety of your drinking water by protecting underground aquifers from contamination. The WHPPs developed by the Department of Water Resources meet or exceed all State and Federal requirements and are specific to your region. For more information about Well Head Protection in your community or to learn how you can help protect the groundwater, contact the Department of Water Resources at (775) 954-4612. You can view the WHPP for your community online at www.washoecounty.us/water.

Terms & Abbreviations

In this report you may find terms or abbreviations that may not be familiar. To help you better understand these terms we have provided the following definitions:

Terms and Abbreviations	Definition
Action Level (AL)	the concentration of a contaminant that, if exceeded, triggers requirements that a water system must follow.
Maximum Contaminant Level (MCL)	the "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.
Maximum Contaminant Level Goal (MCLG)	the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG's allow for a margin of safety.
Non-Detects (ND)	laboratory analysis indicates that the constituent is not present.
Parts per Billion (ppb)	or micrograms per liter (µg/L)
Parts per Million (ppm)	or milligrams per liter (mg/L)
Picocuries per Liter (pCi/L)	picocuries per liter is a measure of the radioactivity in water.
Running Annual Average (RAA)	running annual average (RAA) is calculated by averaging the four (4) most recent quarters of readings.

Water Quality Data

The tables following below list all of the drinking water contaminants, which were detected during the 2009 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2009. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. The bottom line is that the water that is provided to you is safe.

Testing Results for Thomas Creek Public Water System

Primary Regulated Contaminants	Collection Date	Compliance Value	Range	Unit	MCL	MCLG	Typical Source
ARSENIC	2008	2	ND - 2	ppb	10	0	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM	2008	0.1	0.049 - 0.1	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	2008	2	1 - 2	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
FLUORIDE	2008	0.2	ND - 0.2	ppm	2	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE	2009	0.93	0.5 - 0.93	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfectants and Disinfection By-Products	Monitoring Period	RAA	Range	Unit	MCL	MCLG	Typical Source
CHLORINE (as Cl ₂)	2009	0.8	0.6 - 1.0	ppm	4	4	Water additive used to control microbes
TOTAL HALOACETIC ACIDS (HAA5)	2009	ND	ND	ppb	60	0	By-product of drinking water disinfection
TOTAL TRIHALOMETHANES (TTHM)	2009	ND	ND	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Date	90 TH Percentile	Range	Unit	AL	Sites Over AL	Typical Source
COPPER	2007	0.232	0.052 - 0.34	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2007	3.5	ND - 8	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits