



TYPICAL SECTION

**NOTES:**

1. SEE STANDARD DETAILS & SPECIFICATIONS AS PROVIDED BY ALL RELEVANT UTILITIES PROVIDERS FOR ALL UTILITIES IN A COMMON TRENCH.
2. MAINTAIN A MINIMUM SEPARATION OF 5 FEET BETWEEN GAS LINE AND WASHOE COUNTY UTILITIES WATER LINE.
3. 5 FEET MINIMUM FROM FINISHED GRADE TO FLOWLINE ON SANITARY SEWER LINE.
4. MINIMUM 7.5' PUBLIC UTILITY/TRAFFIC CONTROL SIGNAGE/PLOWED SNOW EASEMENT IS REQUIRED ON BOTH SIDES OF RIGHT-OF-WAY AS PER STANDARD DETAIL.

DATE	REVISIONS	 STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION UTILITY MAIN LOCATIONS	SECTION NUMBER: 200	
				DRAWING NUMBER: W-205
				DATE: 2/21/2022