


**NOTES:**

1. A SEWER IS ANY NON-POTABLE LINE INCLUDING, BUT NOT LIMITED TO, MAINS AND LATERALS OF SANITARY SEWER, STORM DRAINS, PRESSURIZED FORCE MAINS AND RECLAIMED WASTEWATER.
2. MITIGATED CROSSING DESIGN CAN UTILIZE JOINTLESS PIPE PER THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (SSPWC), OR BSDW APPROVED EQUAL, FOR WATER AND SEWER. NON-SDR35 (ASTM D3212) SEWER PIPE MAY UTILIZE JOINTLESS PIPE OR APPROVED JOINT SEALANT MEETING ASTM C877.
3. NO VERTICAL SEPARATION IS REQUIRED IF THERE IS 10 FEET OR MORE SEPARATION BETWEEN WATER AND SEWER LINES.

DATE	REVISIONS		STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION NUMBER:
			WATER & SEWER SEPARATIONS NOTES	200
			DRAWING NUMBER:	W-206B
			DATE:	2/21/2022