



**NOTES:**

1. ALL MATERIALS AND INSTALLATION PROCEDURES SHALL BE IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (SSPWC) LATEST EDITION.
2. ALL TRENCHING ACTIVITIES SHALL CONFORM TO O.S.H.A. REGULATIONS.
3. COMPACTION SHALL BE PERCENT RELATIVE COMPACTION BASED ON THE MAXIMUM DRY DENSITY AS DETERMINED BY ASTM D1557 AND WITHIN  $\pm 2\%$  OF OPTIMUM MOISTURE CONTENT.
4. IN HIGH GROUND WATER, CLASS "C" BEDDING TO HIGH GROUNDWATER MARK TOPPED WITH MIRAFI 140N FILTER FABRIC (OR APPROVED EQUAL) MAY BE USED IN LIEU OF CLASS "A", WITH THE APPROVAL OF THE ENGINEER.

DATE	REVISIONS		STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION NUMBER: 200
			SANITARY SEWER TRENCH DETAIL	DRAWING NUMBER: W-207
				DATE: 2/21/2022