



NOTES:

1. RESTRAINED LENGTH CALCULATIONS MUST BE PREPARED AND PROVIDED BY A NEVADA LICENSED ENGINEER.
2. COMBINATION AIR VALVES TO BE INSTALLED AT ALL HIGH POINTS AND TO BE SIZED BY THE ENGINEER.
3. ALL CROSSINGS CLEARANCES AND PROTECTIONS SHALL CONFORM TO NAC 445A.
4. ALL FITTINGS SHALL CONFORM TO AWWA C110, C153 AND/OR C111.
5. MINIMUM DEPTH TO TOP OF PIPE = 42" IF ELEVATION > 5000'.

DATE	REVISIONS



STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION

WATER LINE OFFSET

SECTION NUMBER: 300
DRAWING NUMBER: W-330
DATE: 2/21/2022