

8/23/2019

Washoe County Water ResourcesCSD  
PO Box 11130  
Reno, NV 89502  
Attn: Ben Jesch

OrderID: 19071147

Dear: Ben Jesch

This is to transmit the attached analytical report. The analytical data and information contained therein was generated using specified or selected methods contained in references, such as Standard Methods for the Examination of Water and Wastewater, online edition, Methods for Determination of Organic Compounds in Drinking Water, EPA-600/4-79-020, and Test Methods for Evaluation of Solid Waste, Physical/Chemical Methods (SW846) Third Edition.

The samples were received by WETLAB-Western Environmental Testing Laboratory in good condition on 7/30/2019. Additional comments are located on page 2 of this report.

If you should have any questions or comments regarding this report, please do not hesitate to call.

Sincerely,



Jennifer Delaney  
QA Specialist

**SPARKS**

475 E. Greg Street, Suite 119  
Sparks, Nevada 89431  
tel (775) 355-0202  
fax (775) 355-0817  
EPA LAB ID: NV00925 - ELAP No: 2523

**ELKO**

1084 Lamaille Hwy  
Elko, Nevada 89801  
tel (775) 777-9933  
fax (775) 777-9933  
EPA LAB ID: NV00926

**LAS VEGAS**

3230 Polaris Ave. Suite 4  
Las Vegas, Nevada 89102  
tel (702) 475-8899  
fax (702) 622-2868  
EPA LAB ID: NV00932

# Western Environmental Testing Laboratory

## Report Comments

Washoe County Water Resources CSD - 19071147

### Specific Report Comments

The submitted samples were received at 30.0 degrees Celsius, which is above the EPA recommended temperature range of 10 degrees Celsius. These results are not valid for compliance purposes. For samples that are hand-delivered to the laboratory, evidence of chilling (received on ice) must be present for samples to be considered acceptable. Once the samples were in WETLAB's custody the samples were chilled properly.

The analysis of the laboratory method blank revealed concentrations of Biochemical Oxygen Demand above the method required limit during the analysis of samples 19071147-001 through 003. We apologize for any inconvenience this may have caused.

### Report Legend

- B -- Blank contamination; Analyte detected above the method reporting limit in an associated blank
- D -- Due to the sample matrix dilution was required in order to properly detect and report the analyte. The reporting limit has been adjusted accordingly.
- HT -- Sample analyzed beyond the accepted holding time
- J -- The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit
- K -- The TPH Diesel Concentration reported here likely includes some heavier TPH Oil hydrocarbons reported in the TPH Diesel range as per EPA 8015.
- L -- The TPH Oil Concentration reported here likely includes some lighter TPH Diesel hydrocarbons reported in the TPH Oil range as per EPA 8015.
- M -- The matrix spike/matrix spike duplicate (MS/MSD) values for the analysis of this parameter were outside acceptance criteria due to probable matrix interference. The reported result should be considered an estimate.
- N -- There was insufficient sample available to perform a spike and/or duplicate on this analytical batch.
- NC -- Not calculated due to matrix interference
- QD -- The sample duplicate or matrix spike duplicate analysis demonstrated sample imprecision. The reported result should be considered an estimate.
- QL -- The result for the laboratory control sample (LCS) was outside WETLAB acceptance criteria and reanalysis was not possible. The reported data should be considered an estimate.
- S -- Surrogate recovery was outside of laboratory acceptance limits due to matrix interference. The associated blank and LCS surrogate recovery was within acceptance limits
- SC -- Spike recovery not calculated. Sample concentration >4X the spike amount; therefore, the spike could not be adequately recovered
- U -- The analyte was analyzed for, but was not detected above the level of the reported sample reporting/quantitation limit

### General Lab Comments

Per method recommendation (section 4.4), Samples analyzed by methods EPA 300.0 and EPA 300.1 have been filtered prior to analysis.

The following is an interpretation of the results from EPA method 9223B:

A result of zero (0) indicates absence for both coliform and Escherichia coli meaning the water meets the microbiological requirements of the U.S. EPA Safe Drinking Water Act (SDWA). A result of one (1) for either test indicates presence and the water does not meet the SDWA requirements. Waters with positive tests should be disinfected by a certified water treatment operator and retested.

Per federal regulation the holding time for the following parameters in aqueous/water samples is 15 minutes: Residual Chlorine, pH, Dissolved Oxygen, Sulfite.

#### **SPARKS**

475 E. Greg Street, Suite 119  
Sparks, Nevada 89431  
tel (775) 355-0202  
fax (775) 355-0817  
EPA LAB ID: NV00925 - ELAP No: 2523

#### **ELKO**

1084 Lamaille Hwy  
Elko, Nevada 89801  
tel (775) 777-9933  
fax (775) 777-9933  
EPA LAB ID: NV00926

#### **LAS VEGAS**

3230 Polaris Ave. Suite 4  
Las Vegas, Nevada 89102  
tel (702) 475-8899  
fax (702) 622-2868  
EPA LAB ID: NV00932

# Western Environmental Testing Laboratory

## Analytical Report

Washoe County Water ResourcesCSD

Date Printed: 8/23/2019

PO Box 11130

OrderID: 19071147

Reno, NV 89502

Attn: Ben Jesch

Phone: (775) 954-4612 Fax: NoFax

PO\Project: Swan Lake / io 49300

Customer Sample ID: Compton

Collect Date/Time: 7/30/2019 11:50

WETLAB Sample ID: 19071147-001

Receive Date: 7/30/2019 13:55

Analyte	Method	Results	Units	DF	RL	Analyzed	LabID
<b>General Chemistry</b>							
Ammonia, as Nitrogen	SM 4500 NH3 D	0.15	mg/L	1	0.050	8/22/2019	NV00925
Total Phosphorous as P	SM 4500-P E	3.0	mg/L	5	0.10	8/2/2019	NV00925
Total Suspended Solids (TSS)	SM 2540D	160	mg/L	1	10	8/1/2019	NV00925
Biochemical Oxygen Demand	SM 5210B	15 B	mg/L	1	2.0	7/31/2019	NV00925
Total Nitrogen	Calc.	9.6	mg/L	1	2.5	8/16/2019	NV00925
<b>Microbiological Analyses</b>							
Total Coliform (MPN)	SM 9223B (Quantitray)	>2419.6	MPN/100ml	1	1.0	7/30/2019	NV00925
Escherichia Coli (MPN)	SM 9223B (Quantitray)	ND	MPN/100ml	1	1.0	7/30/2019	NV00925
<b>Anions by Ion Chromatography</b>							
Chloride	EPA 300.0	330	mg/L	10	10	7/31/2019	NV00925
Nitrate Nitrogen	EPA 300.0	ND D	mg/L	10	1.5	7/31/2019	NV00925
Nitrite Nitrogen	EPA 300.0	ND D	mg/L	10	0.60	7/31/2019	NV00925
Sulfate	EPA 300.0	230	mg/L	10	15	7/31/2019	NV00925
<b>Flow Injection Analyses</b>							
Total Kjeldahl Nitrogen	EPA 351.2	9.6	mg/L	1	0.40	8/16/2019	NV00925
<b>Trace Metals by ICP-OES</b>							
Barium	EPA 200.7	0.098	mg/L	1	0.020	8/6/2019	NV00925
Iron	EPA 200.7	1.3	mg/L	1	0.10	8/6/2019	NV00925
Manganese	EPA 200.7	0.24	mg/L	1	0.010	8/6/2019	NV00925
Nickel	EPA 200.7	ND	mg/L	1	0.030	8/6/2019	NV00925
<b>Trace Metals by ICP-MS</b>							
Arsenic	EPA 200.8	0.084	mg/L	1	0.0050	8/2/2019	NV00925
<b>Sample Preparation</b>							
Trace Metals Digestion	EPA 200.2	Complete		1		8/2/2019	NV00925

Customer Sample ID: Pompe

Collect Date/Time: 7/30/2019 12:15

WETLAB Sample ID: 19071147-002

Receive Date: 7/30/2019 13:55

Analyte	Method	Results	Units	DF	RL	Analyzed	LabID
<b>General Chemistry</b>							
Ammonia, as Nitrogen	SM 4500 NH3 D	ND	mg/L	1	0.050	8/22/2019	NV00925
Total Phosphorous as P	SM 4500-P E	0.67	mg/L	1	0.020	8/2/2019	NV00925

DF=Dilution Factor, RL=Reporting Limit, ND=Not Detected or &lt;RL

Page 3 of 7

**SPARKS**

475 E. Greg Street, Suite 119  
 Sparks, Nevada 89431  
 tel (775) 355-0202  
 fax (775) 355-0817  
 EPA LAB ID: NV00925 - ELAP No: 2523

**ELKO**

1084 Lamoille Hwy  
 Elko, Nevada 89801  
 tel (775) 777-9933  
 fax (775) 777-9933  
 EPA LAB ID: NV00926

**LAS VEGAS**

3230 Polaris Ave. Suite 4  
 Las Vegas, Nevada 89102  
 tel (702) 475-8899  
 fax (702) 622-2868  
 EPA LAB ID: NV00926

Customer Sample ID: Pompe

Collect Date/Time: 7/30/2019 12:15

WETLAB Sample ID: 19071147-002

Receive Date: 7/30/2019 13:55

Analyte	Method	Results	Units	DF	RL	Analyzed	LabID
Total Suspended Solids (TSS)	SM 2540D	ND	mg/L	1	10	8/1/2019	NV00925
Biochemical Oxygen Demand	SM 5210B	5.6 B	mg/L	1	2.0	7/31/2019	NV00925
Total Nitrogen	Calc.	ND	mg/L	1	2.5	8/16/2019	NV00925
<b>Microbiological Analyses</b>							
Total Coliform (MPN)	SM 9223B (Quantitray)	>2419.6	MPN/100ml	1	1.0	7/30/2019	NV00925
Escherichia Coli (MPN)	SM 9223B (Quantitray)	ND	MPN/100ml	1	1.0	7/30/2019	NV00925
<b>Anions by Ion Chromatography</b>							
Chloride	EPA 300.0	120	mg/L	10	10	7/31/2019	NV00925
Nitrate Nitrogen	EPA 300.0	ND D	mg/L	10	1.5	7/31/2019	NV00925
Nitrite Nitrogen	EPA 300.0	ND D	mg/L	10	0.60	7/31/2019	NV00925
Sulfate	EPA 300.0	110	mg/L	10	15	7/31/2019	NV00925
<b>Flow Injection Analyses</b>							
Total Kjeldahl Nitrogen	EPA 351.2	1.8	mg/L	1	0.40	8/16/2019	NV00925
<b>Trace Metals by ICP-OES</b>							
Barium	EPA 200.7	ND	mg/L	1	0.020	8/6/2019	NV00925
Iron	EPA 200.7	0.17	mg/L	1	0.10	8/6/2019	NV00925
Manganese	EPA 200.7	0.018	mg/L	1	0.010	8/6/2019	NV00925
Nickel	EPA 200.7	ND	mg/L	1	0.030	8/6/2019	NV00925
<b>Trace Metals by ICP-MS</b>							
Arsenic	EPA 200.8	0.025	mg/L	1	0.0050	8/2/2019	NV00925
<b>Sample Preparation</b>							
Trace Metals Digestion	EPA 200.2	Complete		1		8/2/2019	NV00925

Customer Sample ID: Jean

Collect Date/Time: 7/30/2019 12:30

WETLAB Sample ID: 19071147-003

Receive Date: 7/30/2019 13:55

Analyte	Method	Results	Units	DF	RL	Analyzed	LabID
<b>General Chemistry</b>							
Ammonia, as Nitrogen	SM 4500 NH3 D	0.079	mg/L	1	0.050	8/22/2019	NV00925
Total Phosphorous as P	SM 4500-P E	0.96	mg/L	2	0.040	8/2/2019	NV00925
Total Suspended Solids (TSS)	SM 2540D	18	mg/L	1	10	8/1/2019	NV00925
Biochemical Oxygen Demand	SM 5210B	5.3 B	mg/L	1	2.0	7/31/2019	NV00925
Total Nitrogen	Calc.	ND	mg/L	1	2.5	8/16/2019	NV00925
<b>Microbiological Analyses</b>							
Total Coliform (MPN)	SM 9223B (Quantitray)	>2419.6	MPN/100ml	1	1.0	7/30/2019	NV00925
Escherichia Coli (MPN)	SM 9223B (Quantitray)	172.3	MPN/100ml	1	1.0	7/30/2019	NV00925
<b>Anions by Ion Chromatography</b>							
Chloride	EPA 300.0	110	mg/L	10	10	7/31/2019	NV00925
Nitrate Nitrogen	EPA 300.0	ND D	mg/L	10	1.5	7/31/2019	NV00925
Nitrite Nitrogen	EPA 300.0	ND D	mg/L	10	0.60	7/31/2019	NV00925
Sulfate	EPA 300.0	100	mg/L	10	15	7/31/2019	NV00925
<b>Flow Injection Analyses</b>							
Total Kjeldahl Nitrogen	EPA 351.2	2.0	mg/L	1	0.40	8/16/2019	NV00925

DF=Dilution Factor, RL=Reporting Limit, ND=Not Detected or &lt;RL

Page 4 of 7

**SPARKS**

475 E. Greg Street, Suite 119  
 Sparks, Nevada 89431  
 tel (775) 355-0202  
 fax (775) 355-0817  
 EPA LAB ID: NV00925 - ELAP No: 2523

**ELKO**

1084 Lamoille Hwy  
 Elko, Nevada 89801  
 tel (775) 777-9933  
 fax (775) 777-9933  
 EPA LAB ID: NV00926

**LAS VEGAS**

3230 Polaris Ave. Suite 4  
 Las Vegas, Nevada 89102  
 tel (702) 475-8899  
 fax (702) 622-2868  
 EPA LAB ID: NV00932

Customer Sample ID: Jean

Collect Date/Time: 7/30/2019 12:30

WETLAB Sample ID: 19071147-003

Receive Date: 7/30/2019 13:55

Analyte	Method	Results	Units	DF	RL	Analyzed	LabID
<b><u>Trace Metals by ICP-OES</u></b>							
Barium	EPA 200.7	0.034	mg/L	1	0.020	8/6/2019	NV00925
Iron	EPA 200.7	1.5	mg/L	1	0.10	8/6/2019	NV00925
Manganese	EPA 200.7	0.084	mg/L	1	0.010	8/6/2019	NV00925
Nickel	EPA 200.7	ND	mg/L	1	0.030	8/6/2019	NV00925
<b><u>Trace Metals by ICP-MS</u></b>							
Arsenic	EPA 200.8	0.024	mg/L	1	0.0050	8/2/2019	NV00925
<b><u>Sample Preparation</u></b>							
Trace Metals Digestion	EPA 200.2	Complete		1		8/2/2019	NV00925

**SPARKS**

475 E. Greg Street, Suite 119  
 Sparks, Nevada 89431  
 tel (775) 355-0202  
 fax (775) 355-0817  
 EPA LAB ID: NV00925 - ELAP No: 2523

**ELKO**

1084 Lamaille Hwy  
 Elko, Nevada 89801  
 tel (775) 777-9933  
 fax (775) 777-9933  
 EPA LAB ID: NV00926

**LAS VEGAS**

3230 Polaris Ave. Suite 4  
 Las Vegas, Nevada 89102  
 tel (702) 475-8899  
 fax (702) 622-2868  
 EPA LAB ID: NV00932

## Western Environmental Testing Laboratory QC Report

QCBatchID	QCType	Parameter	Method	Result	Actual	% Rec	Units
QC19071296	Blank 1	Chloride	EPA 300.0	ND			mg/L
		Nitrate Nitrogen	EPA 300.0	ND			mg/L
		Nitrite Nitrogen	EPA 300.0	ND			mg/L
		Sulfate	EPA 300.0	ND			mg/L
QC19080010	Blank 1	Total Coliform (MPN)	SM 9223B (Qu	ND			MPN/100ml
		Escherichia Coli (MPN)	SM 9223B (Qu	ND			MPN/100ml
QC19080092	Blank 1	Total Phosphorous as P	SM 4500-P E	ND			mg/L
QC19080094	Blank 1	Total Suspended Solids (TSS)	SM 2540D	ND			mg/L
QC19080141	Blank 1	Arsenic	EPA 200.8	ND			mg/L
QC19080187	Blank 1	Biochemical Oxygen Demand	SM 5210B	ND			mg/L
QC19080272	Blank 1	Barium	EPA 200.7	ND			mg/L
		Iron	EPA 200.7	ND			mg/L
		Manganese	EPA 200.7	ND			mg/L
		Nickel	EPA 200.7	ND			mg/L
QC19080751	Blank 1	Total Kjeldahl Nitrogen	EPA 351.2	ND			mg/L
QC19080971	Blank 1	Ammonia, as Nitrogen	SM 4500 NH3	ND			mg/L

QCBatchID	QCType	Parameter	Method	Result	Actual	% Rec	Units
QC19071296	LCS 1	Chloride	EPA 300.0	9.94	10.0	99	mg/L
		Nitrate Nitrogen	EPA 300.0	1.99	2.00	100	mg/L
		Nitrite Nitrogen	EPA 300.0	0.492	0.500	98	mg/L
		Sulfate	EPA 300.0	25.8	25.0	103	mg/L
QC19080092	LCS 1	Total Phosphorous as P	SM 4500-P E	0.270	0.250	108	mg/L
QC19080094	LCS 1	Total Suspended Solids (TSS)	SM 2540D	198	200	99	mg/L
QC19080094	LCS 2	Total Suspended Solids (TSS)	SM 2540D	196	200	98	mg/L
QC19080141	LCS 1	Arsenic	EPA 200.8	0.0487	0.050	98	mg/L
QC19080187	LCS 1	Biochemical Oxygen Demand	SM 5210B	228	198	115	mg/L
QC19080272	LCS 1	Barium	EPA 200.7	0.997	1.00	100	mg/L
		Iron	EPA 200.7	0.957	1.00	96	mg/L
		Manganese	EPA 200.7	0.991	1.00	99	mg/L
		Nickel	EPA 200.7	4.94	5.00	99	mg/L
QC19080751	LCS 1	Total Kjeldahl Nitrogen	EPA 351.2	1.08	1.00	108	mg/L
QC19080971	LCS 1	Ammonia, as Nitrogen	SM 4500 NH3 D	0.980	1.00	98	mg/L

QCBatchID	QCType	Parameter	Method	Duplicate Sample	Sample Result	Duplicate Result	Units	RPD
QC19080094	Duplicate 1	Total Suspended Solids (TSS)	SM 2540D	19071074-001	ND	ND	mg/L	<1%
QC19080094	Duplicate 2	Total Suspended Solids (TSS)	SM 2540D	19071147-003	17.5	16.0	mg/L	9 %

QCBatchID	QCType	Parameter	Method	Spike Sample	Sample Result	MS Result	MSD Result	Spike Value	Units	MS %Rec	MSD %Rec	RPD %
QC19071296	MS 1	Chloride	EPA 300.0	19071087-002	99.1	108	108	5	mg/L	85	89	<1
		Nitrate Nitrogen	EPA 300.0	19071087-002	0.722	HT 5.09	5.06	2	mg/L	109	109	<1
		Nitrite Nitrogen	EPA 300.0	19071087-002	ND	HT, 1.07	0.987	0.5	mg/L	101	93	8
		Sulfate	EPA 300.0	19071087-002	30.7	50.8	51.0	10	mg/L	100	102	<1
QC19080092	MS 1	Total Phosphorous as P	SM 4500-P E	19071199-001	0.075	0.326	0.353	0.25	mg/L	100	111	8
QC19080092	MS 2	Total Phosphorous as P	SM 4500-P E	19071024-001	ND	M 0	0	0.25	mg/L	NC	NC	NA
QC19080141	MS 1	Arsenic	EPA 200.8	19071136-002	0.0073	0.0556	0.0556	0.05	mg/L	97	96	<1

DF=Dilution Factor, RL=Reporting Limit, ND=Not Detected or <RL

### SPARKS

475 E. Greg Street, Suite 119  
Sparks, Nevada 89431  
tel (775) 355-0202  
fax (775) 355-0817  
EPA LAB ID: NV00925 - ELAP No: 2523

### ELKO

1084 Lamoille Hwy  
Elko, Nevada 89801  
tel (775) 777-9933  
fax (775) 777-9933  
EPA LAB ID: NV00926

### LAS VEGAS

3230 Polaris Ave. Suite 4  
Las Vegas, Nevada 89102  
tel (702) 475-8899  
fax (702) 622-2868  
EPA LAB ID: NV00932

QCBatchID	QCType	Parameter	Method	Spike Sample	Sample Result	MS Result	MSD Result	Spike Value	Units	MS %Rec	MSD %Rec	RPD %
QC19080272	MS 1	Barium	EPA 200.7	19071136-002	0.100	1.04	1.04	1	mg/L	94	94	<1
		Iron	EPA 200.7	19071136-002	3.28	4.28	4.36	1	mg/L	100	108	2
		Manganese	EPA 200.7	19071136-002	0.125	1.07	1.08	1	mg/L	95	95	<1
		Nickel	EPA 200.7	19071136-002	ND	4.61	4.62	5	mg/L	92	92	<1
QC19080751	MS 1	Total Kjeldahl Nitrogen	EPA 351.2	19071115-005	ND	M 1.55	1.67	1	mg/L	NC	NC	NC
QC19080751	MS 2	Total Kjeldahl Nitrogen	EPA 351.2	19071177-005	ND	M 0.660	0.721	1	mg/L	NC	NC	NC
QC19080971	MS 1	Ammonia, as Nitrogen	SM 4500 NH3	19071064-001	2.10	3.09	3.03	1	mg/L	99	93	2
QC19080971	MS 2	Ammonia, as Nitrogen	SM 4500 NH3	19071073-001	0.434	1.36	1.32	1	mg/L	93	89	3

**SPARKS**

475 E. Greg Street, Suite 119  
 Sparks, Nevada 89431  
 tel (775) 355-0202  
 fax (775) 355-0817  
 EPA LAB ID: NV00925 - ELAP No: 2523

**ELKO**

1084 Lamoille Hwy  
 Elko, Nevada 89801  
 tel (775) 777-9933  
 fax (775) 777-9933  
 EPA LAB ID: NV00926

**LAS VEGAS**

3230 Polaris Ave. Suite 4  
 Las Vegas, Nevada 89102  
 tel (702) 475-8899  
 fax (702) 622-2868  
 EPA LAB ID: NV00932





**WETLAB**  
WESTERN ENVIRONMENTAL TESTING LABORATORY  
*Specializing in Soil, Hazardous Waste and Water Analysis.*

475 E. Greg Street #119 | Sparks, Nevada 89431 | www.WETLaboratory.com  
tel (775) 355-0202 | fax (775) 355-0817  
1084 Lamoille Highway | Elko, Nevada 89801  
tel (775) 777-9933 | fax (775) 777-9933  
3230 Polaris Ave., Suite 4 | Las Vegas, Nevada 89102  
tel (702) 475-8899 | fax (702) 776-6152

WETLAB Order ID. 19071147  
Sparks Control # \_\_\_\_\_  
Elko Control # \_\_\_\_\_  
LV Control # \_\_\_\_\_  
Report Due Date \_\_\_\_\_  
Page \_\_\_\_\_ of \_\_\_\_\_

Client **Washoe County Community Services Department**

Turnaround Time Requirements  
Standard    
5 Day\* (25%)  72 Hour\* (50%)   
48 Hour\* (100%)  24 Hour\* (200%)   
\*Surcharges Will Apply

Address **1001 E. 9th Street**

City, State & Zip **Reno, NV 89512**

Contact **Ben Jesch**

Samples Collected From Which State?  
NV  CA   
Other    
Report Results Via  
PDF  EDD   
Compliance Monitoring?  
Yes  No  Other \_\_\_\_\_  
Report to Regulatory Agency?  
Yes  No  Standard QC Required?  
Yes  No

Phone **(775) 954-4626**

Collector's Name **Fallon Rodriguez**

Fax **(775) 328-3699**

PWS/Project Name **Swan Lake**

P.O. Number \_\_\_\_\_

PWS/Project Number **io 49300**

Email **LPeri@washoecounty.us**

**Analyses Requested**

**Billing Address (if different than Client Address)**  
Company \_\_\_\_\_  
Address \_\_\_\_\_  
City, State & Zip \_\_\_\_\_  
Contact \_\_\_\_\_  
Phone \_\_\_\_\_ Fax \_\_\_\_\_  
Email **LPeri@washoecounty.us**

NO. OF CONTAINERS	Ammonia	BOD / TSS	Total Nitrogen	Total Phosphorus	E. Coli	Chloride / Sulfate	Nitrate / Total Kjeldahl Nitrogen	Arsenic	Barium / Iron	Manganese / Nickel	Spl. No.
5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

SAMPLE ID/LOCATION	DATE	TIME	PRES TYPE	SAMPLE TYPE	NO. OF CONTAINERS
Compton	7/30/19	11:50	Misc.	SW	5
Pompe		12:15	Misc.	SW	5
Jean		12:30	Misc.	SW	5

Instructions/Comments/Special Requirements: \_\_\_\_\_

Sample Matrix Key\*\* DW = Drinking Water WW = Wastewater SW = Surface Water MW = Monitoring Well SD = Solid/Sludge SO = Soil HW = Hazardous Waste OTHER: \_\_\_\_\_

\*SAMPLE PRESERVATIVES: 1=Unpreserved 2=H2SO4 3=NaOH 4=HCl 5=HNO3 6=Na2S2O3 7=ZnOAc+NaOH 8=HCl/VOA Vial

Temp	Custody Seal	# of Containers	DATE	TIME	Samples Relinquished By	Samples Received By
30°C	Y N None	15	07/30/19	1355	<i>[Signature]</i>	<i>[Signature]</i>
°C	Y N None					
°C	Y N None					
°C	Y N None					

**WETLAB'S Standard Terms and Conditions apply unless written agreements specify otherwise. Payment terms are Net 30.**

Client/Collector attests to the validity and authenticity of this (these) sample(s) and, is (are) aware that tampering with or intentionally mislabeling the sample(s) location, date or time of collection may be considered fraud and subject to legal action (NAC445.0636). \_\_\_\_\_ initial  
To the maximum extent permitted by law, the Client agrees to limit the liability of WETLAB for the Client's damages to the total compensation received, unless other agreements are made in writing. This limitation shall apply regardless of the cause of action or legal theory pled or asserted. \_\_\_\_\_ initial  
WETLAB will dispose of samples 90 days from sample receipt. Client may request a longer sample storage time for an additional fee. 301.2E  
Please contact your Project Manager for details. \_\_\_\_\_ initial